

CERTIFICATE

KEMA No.: 99.2708.02

Issued to:

Applicant:

**Koncar Niskonaponske Sklopke
I Prekidaci d.d.
Borongajska B.B.
ZAGREB, Croatia**

Manufacturer/Licensee:

**Koncar Niskonaponske Sklopke
I Prekidaci d.d.
Borongajska B.B.
ZAGREB, Croatia**

Product : main switches and disconnectors

Trade name : KONCAR

Type : GF10

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN (IEC) 60947-3:1999
- an inspection of the production location according to CCA Group Operational Document CCA 204
- a certification agreement with the number 901295

KEMA hereby grants the right to use the KEMA certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: June 25, 1999

C.M. Boschloo
Certification Manager

© Integral publication of this certificate is allowed

N.V. KEMA

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands

P.O. Box 9035, 6800 ET Arnhem, The Netherlands

Telephone +31 26 3 56 28 50, Telefax +31 26 3 51 49 22

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



CERTIFICATE

KEMA No.: 95.9401.02

Issued to:

Applicant:

**Koncar - Niskonaponske Sklopke
i Prekidaci
Borongajska bb
41001 ZAGREB, Croatia**

Manufacturer/Licensee:

**Koncar - Niskonaponske Sklopke
i Prekidaci
Borongajska bb
41001 ZAGREB, Croatia**

Product : switch-disconnector

Trade name : KONCAR

Type/model : GF20

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-3 (IEC 947-3)
- an inspection of the production location according to CCA Group Operational Document CCA 204
- a certification agreement with the number 901295

KEMA hereby grants the right to use the KEMA certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: May 3, 1996

C.M. Boschloo
Certification Manager

© Integral publication of this certificate is allowed

N.V. KEMA

Utrechtseweg 310, Arnhem, The Netherlands
P.O. Box 9035, 6800 ET ARNHEM, The Netherlands
Telephone +31 26 3562850, Telefax +31 26 3514922

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION

